

LYNNWOOD ESTATES (PWS #1280259) SOURCE WATER ASSESSMENT REPORT

August 2, 2001



State of Idaho Department of Environmental Quality

Disclaimer: This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on the data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the state of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

Executive Summary

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the act. This assessment is based on a land use inventory of the designated assessment area, sensitivity factors associated with the wells, and aquifer characteristics.

This report, *Source Water Assessment for Lynnwood Estates (PWS #1280259)*, describes the public drinking water system, the boundaries of the zones of water contribution, and the associated potential contaminant sources located within these boundaries. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. **The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The Lynnwood Estates drinking water system consists of two wells. Well #1 was drilled in 1991 and Well #2 was drilled in 1994. The wells serve approximately 30 people just north of Athol, Idaho. Well #1 was in need of some repairs at the time of the water system's last sanitary survey in 1996. Water samples taken from Well #2 revealed the presence of toluene below the maximum contaminant level in 1994. Additionally, multiple inorganic chemicals have been detected in samples taken from Well #2. A sample taken on 3/5/98 revealed the level of antimony in a water sample to be above the maximum contaminant level. Further testing has shown this contamination to be resolved. Well #1 has not encountered similar problems. Overall, neither well is experiencing significant water quality issues at this time.

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a "pristine" area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

Lynnwood Estates should focus source water protection activities on implementation of practices aimed at maintaining current water quality and preventing a reoccurrence of water samples positive for the presence of contaminants. The water system should develop a source water protection plan to address potential growth in the surrounding area and prevent potential contaminant sites from being located within the wells' source water assessment areas in the future. The protection plan should also include a public education component. Local residents should be made aware of the wells' locations and the locations of their source water assessment areas. They should be advised of methods for the proper use and disposal of household hazardous waste near the wells. The system's protection plan should have a contingency component that outlines emergency response activities and identifies an alternative source of water should one become necessary. Most of the designated area is outside the direct jurisdiction of Lynnwood Estates. Partnerships with state and local agencies and industry groups should be established and are critical to success. Due to the time involved with the movement of ground water, source water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term.

The large number of public water systems in Idaho drawing water from the Rathdrum Prairie Aquifer should consider forming a regional group to represent their interests before state, county and municipal governing bodies when regulatory tools like zoning overlays, or enactment of building codes are the most appropriate ground water protection measures.

A community with a fully developed source water protection program will incorporate many strategies. For assistance in developing protection strategies, please contact your regional Idaho Department of Environmental Quality office or the Idaho Rural Water Association.

SOURCE WATER ASSESSMENT FOR LYNNWOOD ESTATES

Section 1. Introduction- Basis for Assessment

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this source means.** A map showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are attached.

Level of Accuracy and Purpose of the Assessment

The Idaho Department of Environmental Quality (DEQ) is required by the U.S. Environmental Protection Agency (EPA) to assess the over 2,900 public drinking water sources in Idaho for their relative susceptibility to contaminants regulated by the Safe Drinking Water Act. This assessment is based on a land use inventory of the delineated assessment area, sensitivity factors associated with the wells, and aquifer characteristics. All assessments must be completed by May of 2003. The resources and time available to accomplish assessments are limited. Therefore, an in-depth, site-specific investigation to identify each significant potential source of contamination for every public water system is not possible. **This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The ultimate goal of this assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. The Idaho Department of Environmental Quality (DEQ) recognizes that pollution prevention activities generally require less time and money to implement than treating a public water supply system once it has been contaminated. DEQ encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a source water protection program should be determined by the local community based on its own needs and limitations. Wellhead or source water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

Section 2. Conducting the Assessment

General Description of the Source Water Quality

Lynnwood Estates serves a community of approximately 30 people, located just north of Athol, Idaho along Highway 95 (Figure 1). The Lynnwood Estates public drinking water system is comprised of two wells.

Lynnwood Estates is currently not facing water quality issues. The water system samples each well monthly for total coliform bacteria. The most recent positive sample was collected 6/22/01. Prior to that Well #1 had a sample positive for total coliform bacteria on 4/2/97. Well #2 has no prior water samples positive for total coliform bacteria. On 11/15/94 a water sample taken from Well #2 revealed the presence of toluene at 1.11µg/L, well below the maximum contaminant level of 1000.0µg/L. The same water sample revealed the level of manganese to be .07mg/L, above the recommended level of .05mg/L. Manganese is not a regulated contaminant, but can impart taste and color to drinking water. That sample also revealed arsenic at .012mg/L, below the maximum contaminant level of .05mg/L and antimony, above the maximum contaminant level of .006mg/L at .013mg/L. Drilling of the well was completed on 10/21/94, just a short time before the positive samples. Because of this and the lack of contaminated follow-up samples, the positive samples collected on 11/4/94 are likely related to construction activities and not indicative of ground water contamination. A sample taken from Well #2 on 3/5/98 revealed barium at .06mg/L, below the maximum contaminant level of 2.0mg/L and fluoride at .20mg/L, below the maximum contaminant level of 4.0mg/L. Well #1 had a detection of fluoride at .30mg/L on 3/5/98. The water system also samples for nitrate and nitrite, which are at acceptable levels, radiological contaminants, which are below maximum contaminant levels, and lead and copper which have also been satisfactory.

Defining the Zones of Contribution- Delineation

The delineation process establishes the physical area around a well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time of travel zones (zones indicating the number of years necessary for a particle of water to reach a well) for water in the aquifer. DEQ used a refined computer model approved by the EPA in determining the three-year (Zone 1B), six-year (Zone 2), and ten-year (Zone 3) times-of-travel (TOT) for water associated with the Rathdrum Prairie aquifer in the vicinity of Athol, Idaho. The computer model used site specific data, assimilated by DEQ from a variety of sources including the city and other local well logs. The delineated source water assessment area for Lynnwood Estates Well #1 can best be described as a short corridor extending from the well in a northeasterly direction. The delineated source water assessment area for Well #2 can best be described as a slight arc extending from the wellhead northeast to Howard Road. The actual data used by DEQ in determining the source water assessment delineation area are available upon request.

Identifying Potential Sources of Contamination

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act and has a sufficient likelihood of releasing such contaminants at levels that could pose a concern relative to drinking water sources.

The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of ground water contamination. The locations of potential sources of contamination within the delineation area were obtained by field surveys conducted by DEQ and from available databases.

The dominant land use in the area surrounding the Lynnwood Estates drinking water system is rural residential.

It is important to understand that a release may never occur from a potential source of contamination provided best management practices are used at the facility. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation. There are a number of methods that water systems can use to work cooperatively with potential sources of contamination, such as educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

Contaminant Source Inventory Process

A two-phased contaminant inventory of the study area was conducted during May and June of 2001. The first phase involved identifying and documenting potential contaminant sources within the Lynnwood Estates source water assessment area through the use of computer databases and Geographic Information System maps developed by DEQ. The second, or enhanced, phase of the contaminant inventory involved contacting the operator to validate the sources identified in phase one and to add any additional potential sources in the area. This task was undertaken with the assistance of Mike Galante.

There are no documented potential contaminant sites located within the delineated source water area (Table 1).

Table 1. Lynnwood Estates Potential Contaminant Inventory


SITE #	Source Description ¹	TOT Zone ² (years)	Source of Information	Potential Contaminants ³
No documented potential contaminant sites.				

¹UST = underground storage tank

²TOT = time of travel (in years) for a potential contaminant to reach the wellhead

³IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

Figure 1. Geographic Location of the Lynnwood Estates Wells



[illegible]

Section 3. Susceptibility Analysis

The susceptibility of the source to contamination was ranked as high, moderate, or low risk according to the following considerations: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. The following summaries describe the rationale for the susceptibility ranking.

Hydrologic Sensitivity

The wells' hydrologic sensitivity is high. This reflects porous nature of the soils associated with the Rathdrum Prairie aquifer and the lack of significant confining layers retarding the vertical transport of contaminants. The wells are relatively deep, which provides some protection against contamination.

Well Construction

Well construction directly affects the ability of the wells to protect the aquifer from contaminants. Lower scores imply a system that can better protect the water. The Lynnwood Estates drinking water system consists of two wells that extract ground water for domestic use. Water extraction is managed by the system operator.

Well #1

This well was drilled in 1991. The well received a moderate system construction score. The well is 470' deep. An eight-inch steel casing was used. The Idaho Department of Water Resources (IDWR) *Well Construction Standards Rules (1993)* require all public water systems (PWSs) to follow DEQ standards as well. IDAPA 58.01.08.550 requires that PWSs follow the *Recommended Standards for Water Works (1997)* during construction. Various aspects of the standards can be assessed from well logs. Table 1 of the *Recommended Standards for Water Works (1997)* states that 8-inch steel casing requires a thickness of 0.322". Well #1 uses .250" thick casing. The casing extends to 400' and is perforated from 360' to 400'. The casing passes through layers of gravel interspersed with sand and small amounts of clay. The well was sealed to 40' with bentonite.

Well #2

This well also received a moderate system construction score. It was drilled in 1994 and is 394' deep. The well casing is 8" in diameter and .250" thick. The casing extends to the bottom of the well and is perforated from 260' to 283'. The well was sealed to 60' with bentonite. The well was drilled into sand, gravel and boulders with a small amount of clay.

Potential Contaminant Source and Land Use

Both wells rated in the low category for all chemical classes. There are no documented potential contaminant sites located within the wells' source water assessment areas.

Final Susceptibility Ranking

In terms of the total susceptibility score, it can be seen from Table 2 that the wells showed a moderate overall susceptibility in all chemical classes.

Table 2. Summary of Lynnwood Estates Susceptibility Evaluation

Well	Susceptibility Scores ¹									
	Hydrologic Sensitivity	Contaminant Inventory				System Construction	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
1	H	L	L	L	L	M	M	M	M	M
2	H	L	L	L	L	M	M	M	M	M

¹H = High Susceptibility, M = Moderate Susceptibility, Low Susceptibility

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

Susceptibility Summary

The Lynnwood Estates drinking water system is currently not threatened significant sources of contamination.

Section 4. Options for Source Water Protection

The susceptibility assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what the susceptibility ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

An effective source water protection program is tailored to the particular local source water protection area. The State of Idaho and local health districts have instituted enhanced protection of the ground water in the Rathdrum Prairie Aquifer because of its high use and uniquely pristine water quality. The protections are generally aquifer wide and are not aimed at zones of contribution to a specific well or water system. *The Spokane Valley-Rathdrum Prairie Atlas*, sent to water systems on the prairie when they were invited to perform an enhanced contaminant inventory, describes some of the regional protection measures.

The 186 public water systems in Idaho that draw water from the Rathdrum Prairie Aquifer should consider forming a regional group to represent their interests before state, county and municipal governing bodies when regulatory tools like zoning overlays, or enactment of building codes are the most appropriate ground water protection measures.

These types of measures could be used to protect the capture zones of a specific system or group of wells that could be put at risk from local land use changes.

Lynnwood Estates should focus source water protection activities on implementation of practices aimed at maintaining current water quality. The water system should develop a source water protection plan that addresses public education, contaminant site management and contingency planning. Local residents should be notified of the wells' locations and the locations of the wells' source water assessment areas. They should be instructed on the proper use and disposal of household hazardous waste within these areas. The water system should attempt to prevent contaminant sites from being located within the wells' source water assessment areas in the future. Partnerships with state and local agencies and industry groups should be established and are critical to success. A contingency plan that outlines the steps to be taken in the event of a drinking water emergency should be developed. The contingency plan should also identify an alternative source of water should one become necessary. Due to the time involved with the movement of ground water, wellhead protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term.

Assistance

Public water supplies and others may call the following IDEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the IDEQ office for preliminary review and comments.

Coeur d'Alene Regional IDEQ Office (208) 769-1422

State IDEQ Office (208) 373-0502

Website: <http://www.deq.state.id.us>

Water suppliers serving fewer than 10,000 persons may contact John Bokor, Idaho Rural Water Association, at 1-800-962-3257 for assistance with wellhead protection strategies.

References Cited

Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 1997. "Recommended Standards for Water Works."

Idaho Department of Environmental Quality, 1997. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.

Idaho Department of Water Resources, 1993. Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules. IDAPA 37.03.09.

Attachment A

Lynnwood Estates Susceptibility Analysis Worksheets

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.2)
- 2) Microbial Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.35)

Final Susceptibility Scoring:

- 0 - 5 Low Susceptibility
- 6 - 12 Moderate Susceptibility
- > 13 High Susceptibility

1. System Construction		SCORE			
Drill Date	02/06/1991				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	1996			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	NO	1			
Casing and annular seal extend to low permeability unit	NO	2			
Highest production 100 feet below static water level	YES	0			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		4			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	YES	0			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		5			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	OTHER	0	0	0	0
Farm chemical use high	NO	0	0	0	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		0	0	0	0
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	NO	0	0	0	0
(Score = # Sources X 2) 8 Points Maximum		0	0	0	0
Sources of Class II or III leachable contaminants or	NO	0	0	0	
4 Points Maximum		0	0	0	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B Less Than 25% Agricultural Land		0	0	0	0
Total Potential Contaminant Source / Land Use Score - Zone 1B		0	0	0	0
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	NO	0	0	0	
Sources of Class II or III leachable contaminants or	NO	0	0	0	
Land Use Zone II Less than 25% Agricultural Land		0	0	0	
Potential Contaminant Source / Land Use Score - Zone II		0	0	0	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	NO	0	0	0	
Sources of Class II or III leachable contaminants or	NO	0	0	0	
Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0	
Total Potential Contaminant Source / Land Use Score - Zone III		0	0	0	0
Cumulative Potential Contaminant / Land Use Score		0	0	0	0
4. Final Susceptibility Source Score		9	9	9	9
5. Final Well Ranking		Moderate	Moderate	Moderate	Moderate

1. System Construction		SCORE			
Drill Date	10/21/1994				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	1996			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	NO	2			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		4			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	YES	0			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		5			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	OTHER	0	0	0	0
Farm chemical use high	NO	0	0	0	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		0	0	0	0
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	NO	0	0	0	0
(Score = # Sources X 2) 8 Points Maximum		0	0	0	0
Sources of Class II or III leachable contaminants or 4 Points Maximum	NO	0	0	0	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B Less Than 25% Agricultural Land		0	0	0	0
Total Potential Contaminant Source / Land Use Score - Zone 1B		0	0	0	0
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	NO	0	0	0	
Sources of Class II or III leachable contaminants or	NO	0	0	0	
Land Use Zone II Less than 25% Agricultural Land		0	0	0	
Potential Contaminant Source / Land Use Score - Zone II		0	0	0	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	NO	0	0	0	
Sources of Class II or III leachable contaminants or	NO	0	0	0	
Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0	
Total Potential Contaminant Source / Land Use Score - Zone III		0	0	0	0
Cumulative Potential Contaminant / Land Use Score		0	0	0	0
4. Final Susceptibility Source Score		9	9	9	9
5. Final Well Ranking		Moderate	Moderate	Moderate	Moderate

Potential Contaminant Inventory

List of Acronyms and Definitions

AST (Aboveground Storage Tanks) – Sites with aboveground storage tanks.

Business Mailing List – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

CERCLIS – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as **ASuperfund®** is designed to clean up hazardous waste sites that are on the national priority list (NPL).

Cyanide Site – DEQ permitted and known historical sites/facilities using cyanide.

Dairy – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

Deep Injection Well – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

Enhanced Inventory – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

Floodplain – This is a coverage of the 100year floodplains.

Group 1 Sites – These are sites that show elevated levels of contaminants and are not within the priority one areas.

Inorganic Priority Area – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

Landfill – Areas of open and closed municipal and non-municipal landfills.

LUST (Leaking Underground Storage Tank) – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

Mines and Quarries – Mines and quarries permitted through the Idaho Department of Lands.)

Nitrate Priority Area – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

NPDES (National Pollutant Discharge Elimination System)

– Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

Organic Priority Areas – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

Recharge Point – This includes active, proposed, and possible recharge sites on the Snake River Plain.

RICRIS – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities) – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

Toxic Release Inventory (TRI) – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

UST (Underground Storage Tank) – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

Wastewater Land Applications Sites – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

Wellheads – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

NOTE: Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.